


Solutions

1.



2.

a) $3 (1 \text{ h}) (80 \text{ kW}) + 2 (1 \text{ h}) (140 \text{ kW}) = 520 \text{ kWh}$

b)

$$E_{in} = \frac{E_{out}}{\eta} = \frac{520 \text{ kWh}}{0.8} = 650 \text{ kWh}$$

c) À 80 kW

$$PLR = \frac{80}{200} = 0.4$$


$$\frac{\eta_{PL}}{\eta_{FL}} = 1.15 - 0.27PLR + 0.12PLR^2 \cong 1.06$$

$$\eta_{PL} = \eta_{FL} \left(\frac{\eta_{PL}}{\eta_{FL}} \right) = 80\% (1.06) = 84.8\%$$

$$\dot{E}_{in} = 80 \text{ kW} / 0.848 = 94.3 \text{ kW}$$

$$E_{in} = (3 \text{ hrs}) (94.3 \text{ kW}) = 283 \text{ kWh}$$

3.



- a) La chaudière 3 brûle environ 250 heures par an
(c.à.d. lorsque la charge totale est supérieure à 400 kW)
- b) Charge totale pendant l'incendie de la chaudière 3 : en orange ci-dessus
 $(250 \text{ h})(200 \text{ kW})(1/2) + (250 \text{ h})(400 \text{ kW}) = 125\,000 \text{ kWh}$
- c) Charge de la chaudière 3 = $(250 \text{ heures})(200 \text{ kW})(1/2) = 25\,000 \text{ kWh}$

$$E_{in} = \frac{E_{out}}{\eta} = \frac{25,000 \text{ kWh}}{0.7} = 35,714 \text{ kWh}$$

4.

a)

$$\dot{W}_{sh} = \frac{\Delta P \cdot \dot{V}}{\eta_p} = \frac{(160 \text{ kPa}) \cdot (15 \text{ L/s})}{0.60} = 4000 \text{ W}$$

b)

les brûleurs sont allumés/éteints

$$input = \frac{output}{\eta} = \frac{85 \text{ kW}}{0.8} = 106.25 \text{ kW} \quad (\text{chaque brûleur})$$

$$2(106.25 \text{ kW}) \frac{1 \text{ m}^3}{10.33 \text{ kWh}} = 20.6 \frac{\text{m}^3}{\text{hr}}$$

c) extraction = 30 + 12 + 22 = 64 kW

ajout = 4 kW (par pompe)

extraction nette = 64 kW - 4 kW = 60 kW

BLR-1 = 60 kW (PLR = 70,6 %)

BLR-2 = 0 kW

5.


a)

heures lorsque la charge totale ≥ 200 kW $\rightarrow 250$ hrs

b) heures où la charge totale < 100 kW (mais > 0 kW)

$\rightarrow 3500 - 750 \cong 2750$ hrs

c) zone entre 100 et 200 kW $\approx 50,000$ kWh



d)

$$\text{input} = \frac{\text{output}}{\eta} = \frac{50000 \text{ kWh}}{0.7} = 71429 \text{ kWh}$$

e)

B-1 100 kW
B-2 100 kW
B-3 40 kW


\leftarrow ANS = 40 kW

f)

$$\text{À } 40 \text{ kW : } \quad \text{PLR} = 40/100 = 0,4$$

$$\frac{\eta_{PL}}{\eta_{FL}} \approx 0.94$$

$$\eta_{PL} = (0.94)82\% = \mathbf{77\%}$$



g)

brûleur marche/arrêt

$$\text{input} = \frac{\text{output}}{\eta} = \frac{100 \text{ kW}}{0.82} \cong 122 \text{ kW each}$$

$$3(122 \text{ kW}) \left(\frac{1 \text{ m}^3}{10.33 \text{ kWh}} \right) \cong \mathbf{35.4 \text{ m}^3/\text{hr}}$$